

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product	Recessed luminaires for general purpose (floor or ground)
Name and address of the applicant	L&L Luce&Light SRL Via Trescalini, 5, 36031 Dueville, Italy
Name and address of the manufacturer	L&L Luce&Light SRL Via Trescalini, 5, 36031 Dueville, Italy
Name and address of the factory	L&L Luce&Light SRL Via Trescalini, 5, 36031 Dueville, Italy
<i>When more than one factory</i>	<input type="checkbox"/> Additional information on page 2
Ratings and principal characteristics	Product data Ratings: 700 mA DC, max 2 W, Class III, IP66, ta 50 °C
Trademark / Brand (if any)	Luce & Light
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	NK1#211000#0A# and NK2#211000#0A#
Additional information	<input checked="" type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60598-2-2:2023 and IEC 60598-1:2020 National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	3509475.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 20 February 2024


Signature: K Xu



**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME****Additional information**

Models NK2#211000#0A#, NK1#211000#0A# composed by the following speaking code:

Value	NK1 or NK2	#	2	1	1	0	0	0	#	0A	#
Variable	-	I	II	III	IV	V	VI	VII	VIII	IX	X

Where the variables on the Model code have the following meaning and values:

I = Numeric variable to identify the installation type and it can assume:

"0" with special outer casing for installation flush with the wall;

"1" with springs for installation on a panel (plasterboard, sheet metal, etc.).

II = "2" fixed value indicating the power supply as constant current (700 mA DC, Class III).

III = "1" fixed value indicating the power input (max 2 W).

IV = "1" fixed value indicating the CRI of the LEDs used as 90.

V = "0" fixed value indicating the type of external control: luminaire without control.

VI = "0" fixed value indicating a diffuser as clear glass without any surface treatment.

VII = "0" fixed value indicating that are not provided any secondary optical accessories.

VIII = numeric/alphabetic variable to identify the CCT of white light source and can assume these values:

"N" for 2200 K;

"F" for 2700 K;

"5" for 3000 K;

"9" for 4000 K.

IX = "0A" fixed value indicating an asymmetric distribution of light.

X = alphabetic variable to identify the color of the glass diffuser (visible surface) and it can assume:

"E" for white color;

"N" for black color.

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 20 February 2024


Signature: K Xu

